

GLENDALE FIRE DEPARTMENT

APPROVED with CONDITIONS


Specific regulations/conditions are noted within this document and be complied prior to complete inspection. This approval is for the Special Event and does not cover the fire code that may require. LOCATIONS OF ATMS or EXITS or OTHERS in these plans, specifications, or drawings are approximate.

THIS APPROVAL SHALL BE SUBJECT TO RE-INSPECTION. Please review all areas noted in the Code to Minor & Major Code violations.

Approved by: Robert Foster, State: 20180627, 08:50:31 - 07:00

APPROVED By rparuz2 at 8:46 am, Jun 27, 2018

# 2018-2019 WESTGATE WATERDANCE PLAZA BEER GARDEN SITE MAP



- Display and activation area (including 10'x10' vendor activations and/or 20'x10' inflatables. Aggregate area of multiple tents and inflatables by site shall not exceed 300 SF)\* (leaving 20' clearance on all sides)
- ATMs (to be 8' from exits)
- ✕ 10' Exit (to remain open with no obstructions)
- ID Stations (maximum of 3, approximate location)
- Beer sales tubs - 10'x10' (approximate location)
- 32'x28'x2' platform/Dump truck - 40'x40' (approximate location)
- 32'x28'x2' platform/Dump truck - 40'x40' (approximate location)
- Beer garden perimeter (e.g., bike racks, barricades, stanchions with retractable belt or rope, temporary gates, etc.)
- Existing tenant patio fencing
- Generator location (if 20+ KW)

\*Westgate to submit for further review for: (i) any membrane structure 400 SF or greater, (ii) generators 20+ KW and/or (iii) stage/platform taller than 2'.  
 \*\*Gates shall swing in direction of egress and be secured by latch release handle.  
 Emergency Contact: (623) 385-7502 (Westgate Security - 24/7/365).

**Beer garden site plan applies to the following events:**

- Arizona Cardinals home games (9/9/18, 9/23/18, 9/30/18, 10/18/18, 10/28/18, 11/18/18, 12/9/18, 12/23/18)
- New Year's Eve (12/31/18)
- Additional dates may be included, upon providing not less than thirty (30) days prior written notice to the City of Glendale

**Total Beer Garden Area (not including fountains): Approx. 19,920 SF**  
**Total Maximum Occupant Load: 3,984**  
**Expected event attendance: 1,000 - 2,000**  
**Minimum exiting width (at 0.1 ratio): 33 feet**