



City of Glendale, AZ

Technical Guideline

Building Safety
Department

Technical Guideline

Interpretation

Modification

Issue Date: June 2, 2016
Code/Section: 2012 IPC 604.8 and 2012 UPC 608.2
Approved: Steve Dudley Building Official
Developed by: Staff
References: 2012 International Plumbing Code and 2012 Uniform Plumbing Code

Issue: Installation of Pressure Reducing Valves for water pressure exceeding 80 pounds per square inch.

Guideline:

It shall be the City of Glendale, Az policy that Pressure Reducing Valves shall be installed when the water pressure in the area exceeds 80 psi. The determining document for this requirement shall be the City of Glendale, Az Pressure Zone Map dated January 2008. Any water meter or service line installed in any area on the map that is "HATCHED" shall require a Pressure Reducing Valve. The location of the Pressure Reducing Valve may be installed right after the meter or may be located downstream of the meter at any point before the water line enters the building.

